

# **GEO-HEAT CENTER**

Oregon Institute of Technology, Klamath Falls, Oregon 97601 541/885-1750 FAX 541/885-1754

John W. Lund, Director Andrew Chiasson Tonya "Toni" Boyd Debi Carr

#### EXECUTIVE SUMMARY

The Geo-Heat Center conducted a preliminary assessment of the feasibility of a geothermal heat pump (GHP) system at the new planned Schitsu'umsh Cultural Center, located in Plummer, ID. This work has been funded and completed under Midwest Research Institute, National Renewable Energy Laboratory (NREL) Task Order No. KLDJ-5-55052-05, *"Feasibility Studies for Projects in Utah, Nevada, and Idaho"*. In summary, we considered three options for the geothermal part of the system: (i) an open-loop with supply and injection well, (ii) a vertical borehole, closed-loop earth heat exchanger, and (iii) a horizontal closed-loop earth heat exchanger.

#### Estimation of the Heating and Cooling Loads and the HVAC System

The heating and cooling loads at this preliminary stage were estimated using software tools. The peak cooling load is estimated at about 1.164 million Btu/hr (97 tons) and the peak heating load is estimated at about 1.138 million Btu/hr.

A conventional heating, ventilating, and air-conditioning (HVAC) system has not been designed at this time. It is the Geo-Heat Center's opinion, due to the aesthetics of the planned building that the lowest cost type of system would be a series of split systems with natural gas heating and DX cooling. Typical installed costs for these types of systems range from  $10/\text{ft}^2$  to  $12/\text{ft}^2$  of floor space.

Based on recent case studies by the Geo-Heat Center, "inside the building" mechanical and plumbing work associated with geothermal heat pump systems can be installed for about  $11/\text{ft}^2$  of floor space. This was the assumed cost for this study.

#### **Geological Conditions**

Review of well logs in the vicinity of the Plummer, ID area shows that the area is underlain by approximately 10 ft of clay, and then alternating layers of hard and broken basalt rock. Groundwater occurs in broken rock layers in varying quantities and reported temperatures of 50-56°F. Wells drilled to depths less than 500 ft report total yields on the order of 100 to 200 gpm, except for a well owned by the Coeur d'Alene Tribe, which is a 545-ft deep well yielding only 2 gpm Thus, the site geology would be more suitable for either an open-loop or horizontal closed-loop geothermal heat exchange system. Vertical closed-loops are generally difficult and costly to install in hard and broken rock conditions.

#### Open-Loop Geothermal Option

This type of system would consist of a production well and an injection well. The groundwater loop would be isolated from the building loop with a plate heat exchanger. Assuming 55°F groundwater, it is estimated that a well yielding 175 gpm could handle the peak loads.

#### Vertical Closed-Loop Geothermal Option

This type of system would consist of a network of vertical boreholes, each consisting of a high-density polyethylene (HDPE) plastic u-tube heat exchanger. The required total borehole heat exchanger length is

dependent on the average underground earth temperature and thermal properties. It is estimated that the new building will require about 60 vertical boreholes, each 250 ft deep. At 20-ft lateral spacing, this would take up just under half an acre of land area. Prior to final design, a test hole should be drilled and a thermal conductivity test be conducted.

#### Horizontal Closed-Loop Geothermal Option

This type of system would consist of a very compact network of buried "slinky" coils. Horizontal loops require much more pipe than vertical loops because they are buried at depths that still experience some seasonal temperature fluctuations, and thus burial depths should be no less than 6-8 ft. The estimated size of a horizontal loop for the new building would take up about 1 acre of land area.

#### Economic Comparison of Alternatives

The following table summarizes the economics of the proposed geothermal project. The energy savings are based on electricity rates from Kootenai Electric Cooperative.

HVAC System	Typical Installed Cost (Inside the Building) (\$/sq. ft of floor space)	Typical Installed Cost (Geothermal Earth Work) <i>(\$/ton of cooling)</i>	Total Installed System Cost	Annual Energy Savings	Simple Payback On energy Savings (yrs)
Conventional	\$11.00	-	\$462,000	-	-
Open-Loop Geothermal	\$11.00	\$750	\$534,750	\$10,400	7
Vertical Closed-Loop Geothermal	\$11.00	\$1,750	\$631,750	\$10,500	16
Horizontal Closed-Loop Geothermal	\$11.00	\$1,250	\$583,250	\$10,200	12

The most economically-attractive geothermal options are the open-loop and horizontal closed-loop options. A sensitivity analysis done on the capital costs, which is presented in the form of contour maps in this report, show that the worst case cost scenarios increase the payback period to 14 years for an open-loop system, 18 years for a horizontal closed-loop system, and 23 years for a vertical closed-loop system.

#### Greenhouse Gas Analysis

The reduction in greenhouse gas emissions in using a GHP system over a conventional HVAC system is estimated at 68 tons of equivalent  $CO_2$  per year. This is equivalent to removing about 14 cars and light trucks from the road or planting about 80 acres of new forest.

#### Recommendations

The Geo-Heat Center recommends that this is a good time to engage an architect/engineer with geothermal heat pump design qualifications so that the mechanical design can be integrated into the whole building design. More site-specific geologic information is needed such as depth to bedrock, drilling difficulties, and groundwater availability. Ideally, a 500 ft test well could be planned to gather more geologic data in order to make a more informed design decision. Other issues of concern might include timing or constraints of water rights and acceptable land area taken up by a closed-loop heat exchanger.

### **INTRODUCTION**

The Geo-Heat Center conducted a preliminary assessment of the feasibility of a geothermal heat pump (GHP) system at the new planned Schitsu'umsh Cultural Center, located in Plummer, ID. This work has been funded and completed under Midwest Research Institute, National Renewable Energy Laboratory (NREL) Task Order No. KLDJ-5-55052-05, "*Feasibility Studies for Projects in Utah, Nevada, and Idaho*". This assessment is considered preliminary because the building design has not been finalized at this time.

### PURPOSE AND SCOPE

The purpose of this study is to determine the feasibility of using geothermal heat pumps for space heating, ventilating, and air conditioning for the proposed Coeur d'Alene Tribe Schitsu'umsh Cultural Center.

For this preliminary study, the Geo-Heat Center considered the feasibility of three possible options for the geothermal part of the system: (i) open-loop earth heat exchange with a supply and injection well, (ii) a vertical borehole, closed-loop earth heat exchanger, and (iii) a horizontal, closed-loop earth heat exchanger.

### METHOD OF STUDY

The methods and approach conducted by the Geo-Heat Center to accomplish the project objectives are summarized as follows:

- Visited with some members of the design team at the Coeur d'Alene Tribal Headquarters in Plummer, ID and obtained conceptual drawings and preliminary design details of the new cultural center,
- Reviewed water well logs of the area,
- Developed a computer model of the building using eQuest (J.J. Hirsch, 2005) graphical user interface,
- Computed peak hourly and annual heating and cooling loads of the building using the DOE-2 simulation engine (York and Cappiello, 1981),
- Simulated annual energy use of the HVAC system using the DOE-2 building simulation software.
- Conducted an economic analysis of the alternative GHP system, along with an associated sensitivity analysis of cost assumptions,
- Conducted a greenhouse gas analysis to estimate the possible reduction in greenhouse gas emissions by using geothermal heat pumps. This analysis was done using RetScreen software (NRC, 2005).

### HEATING AND COOLING LOADS ANALYSIS

A computer model of the building was developed in order to estimate design loads, but more importantly to estimate annual energy consumption of the HVAC system.

A single-story community center with a total floor area of  $42,000 \text{ ft}^2$  was modeled with the eQuest/DOE-2 software using weather data for Spokane, Washington. Occupancy schedules for people, lighting, and equipment usage for a typical community center building were assumed. Heat recovery of outdoor ventilation air was also modeled, assuming a 75% heat exchanger effectiveness at peak design conditions. Outdoor air handling is explained in further detail below.

The peak and total annual heating and cooling loads for the building as determined from the DOE-2 software were entered into RETScreen, a simple tool developed by Natural Resources Canada (2005) for subsequent economic and greenhouse gas analyses of a geothermal heat pump system (Figure 1). As shown in Figure 1, the peak cooling load is estimated at 1.164 million Btu/hr (97 tons) and the peak heating load is estimated at 1.138 million Btu/hr. The annual heating and cooling demands are estimated at 917.3 million Btu and 858.6 million Btu, respectively.

ite Conditions		Estimate	Notes/Range
Nearest location for weather data		Spokane, WA	See Weather Database
Heating design temperature °C		-13.6	-40.0 to 15.0
Cooling design temperature	°C	31.1	10.0 to 40.0
Average summer daily temperature range	°C	14.1	5.0 to 15.0
Cooling humidity level	-	Medium	
Latitude of project location	°N	47.6	-90.0 to 90.0
Mean earth temperature	°C	12.0	Visit NASA satellite data site
Annual earth temperature amplitude	°C	12.0	5.0 to 20.0
Depth of measurement of earth temperature	m	3.0	0.0 to 3.0
	r		
uilding Heating and Cooling Load		Estimate	Notes/Range
Type of building	-	Commercial	
Available information	-	Energy use data	
		Lifergy use uata	
Design heating load	kW	333.5	
Design heating load	kW million Btu/h	07	
Design heating load Annual heating energy demand		333.5	
	million Btu/h	333.5 1.138	
	million Btu/h MWh	333.5 1.138 268.8	
Annual heating energy demand	million Btu/h MWh million Btu	333.5 1.138 268.8 917.3	
Annual heating energy demand	million Btu/h MWh million Btu kW	333.5 1.138 268.8 917.3 341.2	

#### RETScreen<sup>®</sup> Heating and Cooling Load Calculation - Ground-Source Heat Pump Project

Version 3.1

© Minister of Natural Resources Canada 1997-2005.

NRCan/CETC - Varennes

Figure 1. Summary of peak and annual heating and cooling loads, along with design weather data.

### **OUTDOOR AIR HANDLING**

It was mentioned above that the computer model of the building included a heat recovery system for outdoor air. Current mechanical codes call for fresh ventilation air to be brought in to all buildings, and ventilation rates were described in the Pre-Design Report by ALSC Architects (March 2006). Fresh outdoor air improves occupant comfort and indoor air quality. On extreme weather days, introducing very cold or very hot air to the HVAC equipment results in the necessity of very large-capacity equipment to handle extra the loads. Rather than grossly oversizing equipment to handle these extra outdoor air loads, an energy-efficient way of introducing outdoor air is with heat recovery units as shown in Figure 2.




Figure 2. Example rooftop heat recovery unit for outdoor air handling.

Heat recovery units are almost essential in commercial geothermal heat pump systems, since they can considerably reduce heat pump capacity as well as earth loop size, which significantly reduces capital cost. These units can be installed in attic spaces or closets, and draw in and exhaust outdoor air through decorative louvers.

### CONVENTIONAL HVAC SYSTEM

In order to evaluate the economic feasibility of a geothermal heat pump system, a *base* conventional HVAC system needs to be established. Given the size and layout of the planned building, split systems with natural gas heating and direct-expansion (DX) cooling with remote condenser units would likely be the most practical, lowest-cost option. Another possible conventional HVAC system might be single-zone and multi-zone rooftop units, but these would be difficult to install on a building with a pitched roof.

### SITE GEOLOGICAL CONDITIONS


In order to assess the feasibility of a geothermal heat pump system, some knowledge of the subsurface geological conditions is required. There are a number of documented water wells drilled in the Plummer area, and logs of these wells have been obtained from the Idaho Department of Water Resources, some of which are included in Appendix A.

Review of water well logs in the area shows that the site is underlain by clay and basalt. A surficial layer of clay is present to a depth of approximately 10 ft, underlain by layers of basalt rocks that are described in the logs as hard or broken rock. A modest amount of groundwater is also present in the fractured layers of basalt. Reported well yields range from 100 to 200 gpm, except for a well owned by the Coeur d'Alene Tribe, which was drilled to a depth of 545 ft and only produced 2 gpm.

Based on the site geological conditions, the most favorable type of earth coupling for a geothermal heat pump system is either a horizontal closed-loop or an open-loop with groundwater wells. Vertical closed-loops are generally difficult and costly to install in hard and broken rock conditions.

#### POSSIBLE GEOTHERMAL HEAT PUMP SYSTEM DESIGNS

A conceptual drawing of a geothermal heat pump system is shown in Figure 3. In addition to energy savings, geothermal heat pump systems have several architectural advantages over conventional systems. Geothermal heat pumps require little to no floor space and require smaller mechanical rooms and no outdoor equipment. The absence of outdoor equipment is a good aesthetic advantage for a building like the Schitsu'umsh Cultural Center. The heat pump itself can be placed closer to the zone it serves, thereby reducing long duct runs. Coupled with heat recovery units, the heat pump capacity can be more closely matched with actual zone loads.



**Figure 3**. Conceptual drawing of a geothermal heat pump system in a low-rise office building showing different heat pump types.

In addition to the "inside the building" equipment, geothermal heat pump systems require some type of earth heat exchange system. In this study, we examine the feasibility of (i) an open-loop system, (ii) a vertical bore closed-loop system, and (iii) a horizontal closed-loop system.

### **Option (i): Open-Loop System**

A conceptual diagram of an open-loop system is shown in Figure 4. The system consists of two "loops" separated by a stainless steel plate heat exchanger, which isolates groundwater from the heat pump equipment. This configuration reduces any scale or corrosion to the heat exchanger. Routine maintenance and cleaning of the stainless steel plates usually results a trouble-free system. The building piping loop would be filled with an antifreeze solution, typically a mixture of water and about 15% propylene glycol.

The use of an isolation heat exchanger also allows for energy-efficient control of the well pump. The building loop temperature is allowed to "float" between a heating and cooling setpoint, and when the building loop temperature reaches either of these setpoints, the well pump is energized and moderates the building loop temperature. With this type of control, the required groundwater flow rate is a function of its temperature. Assuming an average groundwater temperature of 55°F, for the conceptual design of the Schitsu'umsh Cultural Center, about 150 gpm of groundwater would be required for peak cooling and about 175 gpm of groundwater would be variable speed.




Figure 4. Conceptual diagram of an open-loop geothermal heat pump system.

The main advantage of this type of system over the closed-loop systems is that they can be the lowest cost option if enough groundwater is available, which there appears to be in the Plummer, ID area. In general, only two drill holes are required: one for the supply well and one for the injection well. The Coeur d'Alene Tribe would be required to secure a water right for non-consumptive use, in addition to a subsurface injection permit.


### **Option (ii): Horizontal Closed-Loop System**

A conceptual diagram of a horizontal closed-loop system is shown in Figure 5. The closed-loop heat exchanger consists of a network of high-density polyethylene (HDPE) plastic pipe. Different configurations are possible; the "slinky" type is a more compact arrangement, but

requires more pipe due to increased thermal interference between adjacent loops. The entire ground loop is filled with an antifreeze solution, typically a water + 15% propylene glycol mixture, which circulates through both the building and ground loops. For energy efficiency, the circulating pump should be variable speed.

Horizontal loops require much more buried pipe than vertical loops because they are buried at depths that still experience some seasonal temperature fluctuations, and this is their main disadvantage with respect to vertical closed-loop systems. To minimize these fluctuations, especially with a commercial building, the loop should be buried at depths no shallower than 6-8 ft. However, since specialized drilling is not required, horizontal systems can be installed at lower cost than vertical systems in many cases. Their advantage over an open-loop systems is that pumping of groundwater and dealing with associated regulations are avoided.

For this preliminary study, a very compact "slinky" horizontal loop would be necessary in order to fit it within a reasonable space. The estimated size of the horizontal loop would take up about one acre.



**Figure 5**. Conceptual diagram of a horizontal closed-loop geothermal heat exchanger.

#### **Option (iii): Vertical Closed-Loop System**

A conceptual diagram of a vertical closed-loop system is shown in Figure 6. The closed-loop heat exchanger consists of a network of HDPE plastic u-tubes installed in vertical boreholes at typical depths of 200 to 300 ft deep. The entire ground loop is filled with an antifreeze solution, typically a water + 15% propylene glycol mixture, which circulates through both the building and ground loops. For energy efficiency, the circulating pump should be variable speed.

The length of the borehole heat exchanger system is a function mainly of the building thermal loads profile and the thermal properties of the ground. In systems of the size that would be anticipated at the new Schitsu'umsh Cultural Center, it is recommended that an in-situ thermal conductivity test be done to determine the soil/rock thermal properties to aid in the proper design of the borehole network. More importantly, it would give information on the geology and difficulty of drilling at the site. For this preliminary study, the drilling requirements are estimated at 60 vertical boreholes, each 250 ft deep at 20 ft lateral spacing. This would take up about 18,000 ft<sup>2</sup> of land area (i.e. just less than half an acre).

The main advantage of the vertical closed-loop system over open-loop systems is that handling of groundwater and dealing with associated regulations are avoided. The advantage over horizontal closed-loop systems is that less pipe is required and considerably less land area is taken up. The main disadvantage of vertical closed-loop systems is the high cost of drilling multiple vertical boreholes, particularly in difficult geological environments.




Figure 6. Conceptual diagram of a vertical closed-loop geothermal heat exchanger.

#### ECONOMIC COMPARISON OF ALTERNATIVES

As previously mentioned, the lowest cost conventional HVAC system, and thus the one assumed for this study would be a number of single-zone split system with natural gas heat and DX cooling. Typical installed costs for these types of systems range from  $10/\text{ft}^2$  to  $12/\text{ft}^2$  of floor space. This does not include the cost of a natural gas pipeline, which would need to be brought to the site.

Energy costs used for this feasibility study were based on electricity rate schedules from Kootenai Electric Cooperative. Electricity rates are \$0.042/kWh with a demand charge of \$200 for the first 50 kW of demand or less, and \$2.50 per kW of demand thereafter. Natural gas rates were estimated at \$1.20/therm.

Based on recent case studies done by the Geo-Heat Center (GHC, 2005), the following estimates were made for possible geothermal heat pump systems at the Schitsu'umsh Cultural Center:

- $\$11/\text{ft}^2$  for installed cost "inside the building" mechanical and plumbing work,
- \$500 to \$1,000/ton cost range for open-loop geothermal systems,
- \$1,500 to \$2,000/ton cost range for vertical closed-loop heat exchanger,
- \$1,000 to \$1,500/ton cost range for horizontal closed-loop heat exchanger,
- Annual energy savings estimated from the RETScreen model are:
  - \$10,400 for the open-loop system,
  - \$10,500 for the vertical closed-loop system, and
  - \$10,200 for the horizontal closed-loop system.

The vertical closed-loop system has the greatest energy savings. Open-loop systems have a slightly greater operating cost due to well pump energy. Horizontal closed-loop systems typically have higher energy costs than vertical closed-loop systems due to fluctuating seasonal temperatures at their burial depth. A summary of results of the economic comparison are shown in Table 1. The simple payback periods on energy savings for the open-loop, vertical closed-loop, and horizontal closed-loop are 7, 16, and 12 years respectively.

 Table 1.

 Summary of Economic Comparison of Geothermal Alternatives

HVAC System	Typical Installed Cost (Inside the Building) (\$/sq. ft of floor space)	Typical Installed Cost (Geothermal Earth Work) <i>(\$/ton of cooling)</i>	Total Installed System Cost	Annual Energy Savings	Simple Payback On energy Savings (yrs)
Conventional	\$11.00		\$462,000	_	
Open-Loop Geothermal	\$11.00	- \$750	\$482,000 \$534.750	\$10.400	- 7
	+	• • • •	¥ /	,	10
Vertical Closed-Loop Geothermal	\$11.00	\$1,750	\$631,750	\$10,500	16
Horizontal Closed-Loop Geothermal	\$11.00	\$1,250	\$583,250	\$10,200	12

Operating and maintenance (O&M) costs were not considered. O&M costs of closed-loop geothermal heat pump systems are generally lower than conventional systems, mainly because of the fact that geothermal heat pump systems have no outdoor equipment. On the contrary, O&M costs of open-loop geothermal heat pump systems can be higher than conventional systems due to periodic cleaning of the plate heat exchanger and maintenance of the well pump.

#### SENSITIVITY ANALYSIS

In this pre-design stage, there are obviously uncertainties in the actual project costs. Therefore, based on the above economic estimates, a sensitivity analysis of the simple payback period to capital costs of the various scenarios was conducted. Results of the sensitivity analysis are shown in Figures 7, 8, and 9 in the form of contour maps.

A review of Figures 7-9 shows that there can be a wide range of payback periods, depending on the capital cost of both the conventional and the geothermal system. The most attractive economics exist for an open-loop geothermal heat pump system, where the simple payback period can range from less than 1 year to 14 years. The next most economically attractive option is the horizontal closed-loop geothermal heat pump system, where the simple payback period can range from less than 6 years to about 18 years. The simple payback period for a closed-loop vertical system can conceivably range from just under 11 years to over 23 years.






Figure 7. Contour map of simple payback period on energy savings of an openloop geothermal heat exchange system.

Coeur d'Alene Tribe, Schitsu'umsh Cultural Center, Plummer, Idaho Preliminary Feasibility Study for a Geothermal Heat Pump System Geo-Heat Center, November 2006



**Figure 8**. Contour map of simple payback period on energy savings of a closed-loop vertical geothermal heat exchange system.



**Figure 9.** Contour map of simple payback period on energy savings of a closed-loop horizontal geothermal heat exchange system.

### **GREENHOUSE GAS ANALYSIS**

Greenhouse gas emissions have been attributed to various negative impacts on air quality and global weather patterns. As a result, carbon emissions have become regulated in some locations throughout the world. Heating and cooling of buildings is responsible for greenhouse gas emissions through the use of electricity generated by fossil-fuel fired power plants, and by combustion of fossil-fuels directly for heat.

RetScreen software (NRC, 2005) was used to estimate the reduction in greenhouse gas emissions through the use of a GHP system at the Schitsu'umsh Cultural Center. The greenhouse gases considered included carbon dioxide (CO<sub>2</sub>), methane (CH<sub>4</sub>), and nitrous oxides (N<sub>2</sub>O). Carbon emission factors from various electrical power generating methods, along with emission factors from natural gas combustion for heating are used in the software. Kootenai Electric Cooperative purchases electricity from Bonneville Power Administration, which is primarily generated by hydro sources. Therefore, a GHP system will be approximately 100% renewable.

The reduction in greenhouse gas emissions is estimated at 68 tons of equivalent  $CO_2$  per year in using a GHP system over a conventional system. This is equivalent to removing about 14 cars and light trucks from the road or planting about 80 acres of new forest.

#### CONCLUDING SUMMARY AND RECOMMENDATIONS

This preliminary feasibility assessment of installing a geothermal heat pump (GHP) system at the new planned Schitsu'umsh Cultural Center in Plummer, ID has included an estimate of peak hour and total annual heating and cooling loads, and a simple payback analysis of open- and closed-loop geothermal heat pump system options.

Some specific conclusions of this study are as follows:

- A conventional HVAC system for the new Schitsu'umsh Cultural Center has not been designed, but the most likely type of system would be number of split systems with natural gas heating and direct-expansion (DX) cooling. A typical installed cost for this type of system is about \$11/ft<sup>2</sup> of floor space.
- All three geothermal configurations considered are technically possible for the new building, but each has some associated risks. Well logs indicate inter-layered hard and broken basalt, making a vertical closed-loop system potentially cost prohibitive. Likewise, unexpectedly shallow bedrock can hamper excavating for a horizontal closed-loop. The risks involved with choosing an open-loop groundwater system, are that adequate groundwater supply may not be found.
- Existing well logs indicate a good chance of adequate groundwater at the site for an open-loop system, and this type of system would be the lowest cost option and least intrusive to the site. Irrigation water can optionally be supplied by the geothermal well. An open-loop system would require a water right and an injection permit.
- A vertical closed-loop system is estimated to require 60 vertical boreholes, each 250 ft deep with 20-ft lateral spacing, which would take up just less than half an acre of land area. The actual length of the borehole heat exchanger system is a function mainly of the

building thermal loads profile and the thermal properties of the ground. In systems of the size that would be anticipated at the new building, it is recommended that an in-situ thermal conductivity test be done to determine the soil/rock thermal properties, in addition to gaining some insight into the drilling conditions.

- A horizontal closed-loop system would require much more buried pipe than vertical loops because they are buried at depths that still experience some seasonal temperature fluctuations, and this is their main disadvantage with respect to vertical closed-loop systems. A very compact horizontal loop would require about one acre of land area.
- Assuming that the "inside the building" mechanical and plumbing work of a geothermal heat pump system could be done for \$11/ft<sup>2</sup>, an analysis of simple payback on energy savings shows the following approximate payback periods:
  - 7 years an open-loop system,
  - 12 years for a horizontal closed-loop system, and
  - o 16 years for a vertical closed-loop system.

The Geo-Heat Center recommends that this is a good time to engage an architect/engineer with geothermal heat pump design qualifications so that the mechanical design can be integrated into the whole building design. It is also recommended that the owner/operators of the new building meet with the design team and other interested parties to establish the best geothermal option. More site-specific geologic information is needed such as depth to bedrock, drilling difficulties, and groundwater availability. Ideally, a 500 ft test well could be planned to gather more geologic data in order to make a more informed design decision. Other issues of concern might include timing or constraints of water rights and acceptable land area taken up by a closed-loop heat exchanger.

#### **REFERENCES**

ALSC Architects, 20065. Schitsu'umsh Cultural Center, Pre-Design Report.

GHC, 2005. *Geothermal Heat Pump Case Studies of the West*, Geo-Heat Center Quarterly Bulletin, September 2005, Vol. 26, No. 3.

Hirsch, J.J., 2005. eQUEST Energy Simulation Tool.

- Natural Resources Canada (NRC), 2005. Retscreen International, Clean Energy Project Analysis Software.
- York, D.A. and Cappiello, C.C., 1981. *DOE-2 Engineers Manual (Version 2.1A)*, Lawrence Berkeley Laboratory and Los Alamos National Laboratory.

Coeur d'Alene Tribe, Schitsu'umsh Cultural Center, Plummer, Idaho Preliminary Feasibility Study for a Geothermal Heat Pump System Geo-Heat Center, November 2006

### **APPENDIX** A

## WATER WELL LOGS IN THE PLUMMER, ID VICINITY

Form 238-7 IDAHO DEPARTMENT OF WA	
Starships Consulting and WELL DRILLER'S Management Revives	
1. WELL TAG NO. D0040122         Drilling Permit No:       B32463         Other IDWR No.       \$68844         2. OWNER       Well Number;         Name       Plummer, City of C/O USKH ING         Address       621 W Malfon Ave STE 309         City       Spokanc         Bata       WA Zip         9201       State         3. LOCATION OF WELL by legal description         sketch map location must argree with writen location:	11. WELL TESTS:         Image: Pump III Baller         Air       Image: Pump III Baller         Yield gal/min.       Drawdown Pumping Level         Time       Time         Image: Pump III Baller       Air         Yield gal/min.       Drawdown Pumping Level         Image: Pump III Baller       Air         Image: Pump IIII Baller       Air         Image: Pump IIII Baller       Air         Image: Pump IIII Baller       Air         Image: Pump IIIII Baller       Air         Image: Pump IIII Baller       Air         <
Twp.       46       M North or       South         Rge.       4       Eest or       Wwest         Rge.       4       Eest or       Wwest         Soc.       18       NE       1/4       1/4         Gov't Lot       County       BENEWAH         Lat:       Long:       :         *       Address of Weil Site       314       0' Sheet         City       Planmer       City       Planmer         Lt       Blk       31       Sub. Name	12. LITHOLOGIC LOG:(Describe repairs of abandonment)           Bac         From         To           Bac         From         To           6         Notify         From           10         Roget Used         Mater           10         Roget Used         Mater
<ul> <li>4. USE:</li> <li>Domestic <sup>M</sup> Municipal <sup>1</sup> Monitor <sup>1</sup> Intigation Thermal <sup>1</sup> Injection <sup>1</sup> Other <u>1</u></li> <li>5. TYPE OF WORK check all that apply (Replacement, etc.) New Well <sup>1</sup> Modify <sup>1</sup> Abandonment <sup>1</sup> Other <u>Deepened</u></li> <li>6. DRLL #ETHOD</li> </ul>	RECEIVED JUN 0. 2005 DWS/Monte
Air Rotary   Cable □ Mud Rotary □ Othes     SEALING PROCEDURES     SEALIFILTER PACK AMOUNT METHOD     Maternal (From To Secure Paunds     Waternal (From To Secure Paund	
Iniarpager     From     To     Galuge     Material     Coding     Lifer Woldall T-Jaward       Length of heaviprips	
PERFORATIONS/SCREENS     Perforations Method     Screen Type     To Bactain Burnham Blackter Internet     To Bactain Blackter Internet     To Blackter Internet     To Bactain Blackter Internet     To	Completed Depth 150 (Mcasurable) Date: Started 4/13/2005 Completed 4/13/2005 <b>13. DRILLER'S CERTIFICATION</b> We certify that all minimum well construction standards were complied with at the time the rig was removed. Firm Name <b>HSO WellService Inc.</b> Firm No. 448 Firm Official Construction Standards Date 4 -18 - 05 and Supervisor or Operator Date 024/13/05 Louis Henner (Construction Standards)

.

Office Use Only Form 288 / IDAHO DEPARTMENT OF WATER RESOURCES Well ID No. 6/02 WELL DRILLER'S REPORT Inspected by Two \_\_\_\_\_ Rge\_\_ \_ Sec <u>000 40865</u> 1. WELL TAG NO. D \_ 1/4 \_ \_\_\_\_\_1.4 \_\_\_\_ 1/4 DRULING FERMITING. 8-36<u>166</u> 12 WELL TESTS: Lat: Long: : Water Fight or Frection Well No. T Pány I 🔨 Air Daitor J Howing Arles an ed az (m. n. 1 fortheres 2. OWNER: Distance Lead Artift Plumm <u>er Forest</u> Products In LOO gfrom Напе 462 80x . Address . O Plummer Etete ID IV 03051 Cit. . Water Trangs 50 Editor Trole trang. 3. LOCATION OF WELL by legal description: Water Outlify estimates <u>Clear no</u> odor You must provide address or Ltd. Rike Sub, at Directions to well. \_ Depth First Witten - not unter 63 46 IND. North 🙀 Ç**r** South 1 13. LITHOLOGIC LOG: (Describe reports or obendomment) Кдэ. Eas. I -4 May 14 32 X Vieter 20 20 100 ų. N c.ec. . .: Remarks: Librology, Water Quality & Temperature Ŷ, Carty Benewal Goetrict 14 4:11 \_0 Long: Lat: 10 95 Activess of Well Site buy 4.12 clay -Tan Bushlt - Broken or plummer 22 12 and allow as much that the family and the <u>82 58</u> 58 63 Besalt - Gray L1. BK. Sub Name 6 Basult - bra Besalt Broken 63 66 water 4. USE: 25 gpm Brycel updrly. L. Domestic T Municipal Norilar ក្រាត់ស្លាប់រា 66 302 L Thermai П носсол Xillher Log Yard <u>Bosalt</u> Grð Baselt - Broken Whater 302 305 5. TYPE OF WORK bleck of that apply (Peplacement ett.) 22 gpm Clay - Brown Kew 291 Diffectly IT Abandonment Úther 👘 305 310 310315 cla <u>1 - Light Green</u> 5. DRILL METHOD: Basalt - Block + Brown 315 320 XAT Holery C Calify f. Mus Broary (Glhar \_ 50 apm Besalt - 6ray 320 402 7. SEALING PROCEDURES 102410 Clay-Seat reportal 5 200 I. Xaget (\* 5 50 12.54 Gray w/water L. Sea, Flactment Math. d Weight Column 28 gpm clay - Gray -Bestonite Bour Around Pipe 4/0 420 700 462 Basalt - Black Was drive space used / 💦 🗍 K - Sixin Depth(s) 6 Was dive shoe see tealed? 🔀Y T. N. - Haw? 🔄 🐴 📝 100 gpm tatal 8. CASING/LINER: 8, +2 Rei Mater A Снати disci Webcell Unreaced -58 250 Steel Ē. × 127 R. -8 -462.000 Ľ С ongin ol Headpida Longih mi atoipeil Y 🏋 Туре Parker IOWRINION. 8. PERFORATIONS/SCREENS PACKER TYPE Patenzion Mothes 🔄 <u>Dr.: U</u> Screen Type & Mishoo of Installation r..... But Ball Marce Weler/ In pr -14 820 6" Completed Depth 462 -122 -462] <u>€</u>110 11 × Moacuratiic» £ 9-21-05 Daren Saarnee 9-26-05 Completee ٦ I. 14. DRILLER'S CERTIFICATION 10. FILTER PACK We perify that all minimum well construction standards were complete with all the The first of Incement Vicinity line the rig was removed We show the rest hone Corport Nome Action Drilling INC. Form No 618 11. STATIC WATER LEVEL OR ARTESIAN PRESSURE: Prinspollutter Alvin Carris \_200 10-15-05 146 C below ground Anvesian pressure 🔄 👘 Io. and United of Operator II Depart llow encournered 302-1. Describe, appears out or control devices. <del>Сан</del> well Cap Com aun Date 10-15-05 Operator 1 Principal Diffusiand Rig Operator Registran 46N 460 18 Coerator Lucast have signature of Dr LeryOperator 1. FORWARD WHITE COPY TO WATER RESOURCES

······	
	Office Use Only
Form 246 / IDAHO DEPARTMENT OF WATER RESC	OURCES Wellic Na
WELL DRILLER'S REPOR	
1. WELLTAG NO. D 000 40657	Twp Rge Sec
DRILLING PERMIT VE. 836349	12. WELL TESTS; Lat : Long. : :
Water Hight on Meet No.	Fump I Baller INA . Toxing Arrestan
2. OWNER: A C D C	Tel. (e.3) . Experiment Fumping
Hama Mel Doyle	50 gpm Airlift from 200
anoras Milwaukee Rd By St. Mories State ZD / B3861	·
	Water amo. 50 mm Railam hols lamo
3. LOCATION OF WELL by legal description:	Water Usal ty test or comments. Clear no odor
Vet Fust provide address of Lot, Bik, Subtry r Directions to well Map Y & North X or South 1	Depth final Water Encounter 122
Loss II Est The all all and the	13. LITHOLOGIC LOG: (Desotibe repairs or abandonment) Water
Sen. 4 13 1/10/34 5/E 14	Dure Boo To Remedies through Water Ouel ty & Emporature Y N
Goverliet Cooning <i>Ben Europh</i> Lat: : : Long: : :	810 12 Clay- Tan
Milles of Well Sta 405 Ellis Lane	12 28 Basalt Broken
City 1/4 M Br	28 39 Basatt Gray
La 6k Suc Name	6 39 72 Basott Gray
	72 78 Basgit Broken - Brown 78 163 Basgit - Gray
4. USE:	163 168 Basalt - Broken Brown
<ul> <li>With the second second</li></ul>	148 172 Basatt - Gray - Hard
Liberna Dirlegion I One	172 182 Basalt - Broken Master -
5. TYPE OF WORK check all list apply (Poplacement or )	182 200 Baselt Broken Whistor and
Chen Wal Medity 2 Abandonment 7 Science	- 182, 200 Basalt & Broken "Twetter 6-1
	and dat Beself Broken WiRedchy
6. DRILL METHOD: Ø ör Ratary I Cohio L. Mud Rotary T Other	
· · · · · · · · · · · · · · · · · · ·	50 gpm totatel
7. SEALING PROCEDURES	e 200'
Bestagity 0.39 855 Bur Around Pige	
Beatante 0 39 BSE Tour Around Pipe	
Was drive shoe used? XY LIN Shoe Dephys; 39 *	
Was drive since was tested? X* L 6 Haw?	
8. CASING-LINEA:	
Lingmond from To Course Statemat Caping for Welcod To could	-+···
6 +1 -39 250 Steel W X -	NUV 04 ED
4" - <u>B - 200 160 PUC   N</u>	10 mm 7 2005
i engli o' Talgipa	
Рескен П.Ү 🔊 Тула	·    . <u>'η</u>
9. PERFORATIONS/SCREENS PACKER TYPE	
Partoradon Melhod Dr. 11	
Screen type & Mellips of historia ion	· r'
-140-200 - 74 72 W PUC 0 7	Campinized Depart (Measurable)
	Паба, запах 9-27-05 Сопрыла <u>9-28-25</u> 14. DRILLER'S CERTIFICATION
10. FILTER PACK	We detaily instituting in the construction standards were completely to all the
File Melene Doct To Weight Wolume Flass that Network	time the rig was removed.
none.	Company Name Action Drilling Inc. France 618
11. STATIC WATER LEVEL OR ARTESIAN PRESSURE: 38 Address ground Aries an pressure III.	Phropal Driller Aluin, Carris Date (0-15-09 and
Double flow and unitered 17 4 II. Despite agrees port or control new cost	Driller of Operation II Data
Well Cap	Decalar _ aline Carry Date 10-15-05
46N 4N 9	Purcipal Drills: and Fig Clearator Required.
FCI WARD WHITE COPY	Cpersum Linux: https://gitecture.of/CritienCose alor TC WATER RESOLINCES

e.

Form 238-7 IDAHO DEPARTMENT OF WATER RESO	OURCES	Well ID No.	
6/02 WELL DRILLER'S REPORT		Inspected by	
		Twp Rge Sec	
1. WELL TAG NO. D D 0039888		1/4 1/4 1/4 1/4	4
DRILLING PERMIT NO. 930757	12. WELL TESTS:	Lat: : Long: :	
Water Right or Injection Well No.	Pump Bailer	XAir Growing Artesian	
2. OWNER:			Time 🖌
Name Coourd' Alere Tribe	29.p.m. A:		5
2. OWNER: Name <u>Coeurd'Alene Tribe</u> Address PO Box 408	~ <u>77</u>		<b>^</b>
City Plummer State D. Zip 83851			
	Water Temp56°	Bottom hole te	mp.
3. LOCATION OF WELL by legal description:	Water Quality test or comments:	clear no odor	
You must provide address or Lot, Blk, Sub. or Directions to well.	,	Depth first Water Enco	0-1
Twp. <u>4</u> ( North X or South	13. LITHOLOGIC LOG: (Desc		Water
Rge East □ or West 🕅 Sec >>> 1/4 1/4 1/4	Para		
Sec 1/4 1/4 1/4 1/4 Gov't Lot County 1/4 1/4 1/4	Dia. From 10 Remarks:	Lithology, Water Quality & Temperature	Y N
Lat: : Long: : :	12" O 16 Clay	1-Brown	
Address of Well Site 230 Agency Loop Rd. City Plummer	16 25 Clay	r- Tan	
(Give al least riserie of rised - Distance to Role for Landman) City Plummer	10 25 60 Clay	- tan	
(Give at Healthame of Food + Distance to Road or Landmark) Lt. Blk. Sub. Name	60 90 Clay	- Red	
	90 91 Clay.	- Red Sandy Murator	-
		gpm-dirty	+-+-1
4. USE:	91 120 Clay	- Red	+
Domestic Municipal Monitor Irrigation	120 100 Clay-	Tan W/someshale	
Thermal Injection Other	8" 180 260 Shale	- Tan w/ clay	
		- Multi-color-soft	+
5. TYPE OF WORK check all that apply (Replacement etc.)	230 300 Shale	- Multicolar	
New Well 🗌 Modify 📄 Abandonment 🗌 Other	300 360 Gran	ite - Pink + Gray	
6. DRILL METHOD:	360 369 Gran	te-Pinkt Gray ter Igpm	
🕅 Air Rotary 🗌 Cable 🛛 Mud Rotary 🗌 Other	369 482 6rani	Her Igpm	+
1			
7. SEALING PROCEDURES		te-Pinkt Gray	
Seal Material From To Weight / Volume Seal Placement Method	493 545 6	ite Pink + Gray	+
Bentonite O 80 335x Pour Around Pipe	100 575 Gran	THE TIME TOTALY	
Was drive shoe used? XY IN Shoe Depth(s) /85		· · · · · · · · · · · · · · · · · · ·	
Was drive shoe used? $XY \square N$ Shoe Depth(s) <u>185</u> Was drive shoe seal tested? $XY \square N$ How? A)	2	gpm: Total@5	45
		Jporte to the C S	
8. CASING/LINER:			
Diameter From To Gauge Material Casing Liner Welded Threaded			
8" +2 -185 250 Steel X X			
Length of Headpipe Length of Tailpipe		RECEIVED	
Packer Y XN Type			
9. PERFORATIONS/SCREENS PACKER TYPE			
Perforation Method			1
Screen Type & Method of Installation		Li Mi Month	
From To Slot Size Number Diameter Material Casing Liner			
hone			leasurable)
	Date: Started 1-18.	-0.5 Completed 1-2	7-05
	14. DRILLER'S CERTIFICATIO	ON	
10. FILTER PACK	I/We certify that all minimum well of	construction standards were complied wi	th at the
Filter Material From To Weight / Volume Placement Method	time the rig was removed.		
none	Company Name Artim	Drilling Inc. Firm N	6 6.12
· · · · · · · · · · · · · · · · · · ·			
11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:	Principal Driller Aluin	Carris Date 2-	18 05
350_ft. below ground Artesian pressurelb.	and		
Depth flow encountered 368 ft. Describe access port or control devices:	Driller or Operator II	Date	
welded steel plate	Operator   alum		8-05
46N 4W 22	Principal Dril	ller and Rig Operator Required.	
	TO WATER RESOURCES	have signature of Driller/Operator II.	